


GOVERNMENT OF WEST BENGAL  
OFFICE OF THE BLOCK MEDICAL OFFICER OF HEALTH  
MURADIH B.P.H.C, PO-MURADIH, PS-SANTURI, PIN-723156  
DIST-PURULIA

Memo No:- SBHS :242

Date:29-01-2026

TO WHOM IT MAY CONCERN

This is to certified that, DAV Public School, Madhukunda Located at ACC Damodhar Cement Work Campus, Po- Sunuri, Dist- Purulia, has safe drinking water facilities( as per PHE report) for the student and members of staff on the institution and maintaining the hygienic sanitation condition in the school building & the campus norms prescribed by the Central/ State Govt.

  
Block Medical Officer of Health  
Muradih B.P.H.C  
Po- Muradih, Dist- Purulia

Block Medical Officer of Health  
Muradih B.P.H.C P.O.- Muradih  
Purulia

**Annexure C**  
**Appendix-XIII**

**ROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

**No.01**

**Date-17.01.2026**

It is certified that an inspection team headed by Samiran Ukil Technical Manager Purulia district Water Testing Laboratory (Name of Officers with designation) Chemist/Technical Manager from PURULIA DISTRICT WATER TESTING LABORATORY (Name of Department/ Office) inspected the DAV Public School, Madhukunda, PO- Sunuri, Block- Santuri (Name & Address of the school) on 17.01.2026. (date of inspection), checked the water test report Submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

The above is valid for a period of 16.06.2026



Signature with Seal -

Name- Samiran Ukil

Designation: Chemist/Technical Manager

Name & Address of the Office / Department:  
PHE RWS Office, Ranchi road Jal Tanki More,  
Purulia, Pin-723101

SIGNATURE

*S. Ukil 17/01/2026*  
CHEMIST/BACTERIOLOGIST  
District Water Testing Laboratory  
PURULIA DISTRICT WATER TESTING  
LABORATORY, PHE  
Govt. of West Bengal

To DAV PUBLIC SCHOOL, Acc Limited, Damodar Cement Works,  
P.O- Sunuri Madhukunda, Block- Santuri, Purulia (W.B) Pin-723121  
( Name & Address Of The Institution)



**PURULIA DISTRICT WATER TESTING LABORATORY**  
Under  
**PURULIA DIVISION**  
**PUBLIC HEALTH ENGINEERING DIRECTORATE**  
**GOVT. OF WEST BENGAL**  
**TEST REPORT**

<b>Date of Collection:</b> 16.01.2026		<b>Brought By :</b> Staff			
<b>Place of sample-</b> DAV PUBLIC SCHOOL, Acc Limited, Damodar Cement Works, P.O- Sunuri Madhukunda, Block- Santuri, Purulia (W.B) Pin-723121					
<b>Quantity:</b> 1000ml			<b>Mode of packing:</b> PP Bottle		
<b>Analysis started on:</b> 16.01.2026			<b>Analysis Completed :</b> 17.01.2026		
<b>Type of Sample :</b> Boring			<b>Location:</b> DAV PUBLIC SCHOOL		
SL. NO.	PARAMETER	UNIT	RECOMMENDED DRINKING WATER QUALITY as per IS: 10500-2012		Test Result
			Desirable Limit	Permissible Limit(max.)	
<b>A. Physical and Chemical results</b>					
1.	PH		6.5-8.5	No relaxation	7.20
2.	Total Hardness, as CaCO <sub>3</sub>	Mg/l	200	600	99.13
3.	Iron. As Fe	Mg/l	0.3	1.00	0.03
4.	Fluoride	Mg/l	1.00	1.5	0.40
5.	Turbidity	NTU	1	5	0.38
6.	Mn	Mg/l	0.1	0.3	0.02
7.	TDS	Mg/l	500	2000	192
8.	Chloride	Mg/l	250	1000	11.23
9.	R.cl <sub>2</sub>	Mg/l	0.2	1	0.00
10.	Total Alkalinity (CaCO <sub>3</sub> )	Mg/l	200	600	124.20
11.	Calcium (as Ca)	Mg/l	75	200	29.10
12.	Magnesium (as Mg)	Mg/l	30	100	6.33
<b>B. Bacteriological results</b>					
1.	Total Coli form Bacteria	CFU/100 ml	Absent	Absent	Absent
2.	Feacal coli form	CFU/100 ml	Absent	Absent	Absent

Note- All the above parameter are under permissible limit.

SIGNATURE

CHEMIST/BACTERIOLOGIST  
District Water Testing Laboratory

SIGNATURE

*S. Mukherjee*  
17/01/2026  
CHEMIST/BACTERIOLOGIST  
District Water Testing Laboratory  
PURULIA DISTRICT WATER TESTING  
LABORATORY, PHED  
Govt. of West Bengal

